



ADDENDUM NO. 01

DISTRIBUTED BY: Edgardo Nunez, CCS International, Inc.

DATE DISTRIBUTED: 08/29/2024

PROJECT: RFP: HVAC System Upgrades

PAGES INCLUDING ATTACHMENTS: (1) pages.

NOTE: The following changes are hereby made to the Bid Documents and insofar as the original Bid Documents are inconsistent therewith, the changes herein shall govern. All bidders shall acknowledge this Addendum by inserting its number and date on their Bid Proposal.

CLARIFICATIONS TO BIDDER QUESTIONS:

1. We need to know the CURRENT revision of the existing Tridium System. Is it AX or N4 and what revision?
 - Response: The current revision of the existing system is N4.10.
2. Are we to reuse all existing end devices, Sensors, Transmitters, relays, valves, etc?
 - Response: The intent was to leave any and all devices unless the existing devices are not compatible to new controllers. Contractor to make that determination.
3. The RFP calls for all new BAS equipment to be tied into the existing Tridium Niagara front end computer and software. Can the bidders propose other software options?
 - Response: Yes, bidders can propose other software. If alternative software is proposed, all costs are to be included in the bid and the proposed software is to be noted.

CHANGES AND CLARIFICATIONS TO RFP:

1. None.

DRAWINGS:

1. None.

ATTACHMENTS:

1. None.

END OF ADDENDUM NO. 01

